



California State Fire Marshal
CODE INTERPRETATION

Date Issued	12-05-02	Interpretation #	02-042
Topic	Access to a Sprinkler Riser Flow Switch		
Code Section(s)	§110-34, California Electric Code (1998 ed)		
Requested by	William Sallee System Sensor 3825 Ohio Avenue St. Charles, IL 60174		

Is a flow switch on an NFPA 13D riser considered electrical equipment listed in CEC 110-34? If so, are the requirements listed in CEC 110-34 for working space applicable?
No.